

In accordance with the NFPA requirements (NFPA 110), the following checks of the Emergency Generator must be performed once a week. Also required is manual exercising of the generator and transfer switch for a recommended 15 minutes per week.

WEEKLY GENERATOR LOG BOOK

DATE	/ /	/ /	/ /	/ /	/ /	/ /
RUN TIME METER (hrs.)						
FUEL IN MAIN TANK						
FUEL IN DAY TANK						
OIL IN CRANK CASE						
VISIBLE LEAKS (y/n)						
COOLING SYSTEM (level)						
LOUVERS OPERATE (yes/no/na)						
BATTERY WATER LEVEL						
BATTERY CHARGER AMPS						
MAIN CIRCUIT BREAKER (on/off)						
FIELD CIRCUIT BREAKER (on/off)						
VISIBLE EXHAUST - after 10 seconds (y/n)						
VOLTMETER READING						
OIL PRESSURE P.S.I.						
WATER TEMP DEGREES						
FREQUENCY - Hz						
AMMETER - AMPS						
AMPS - % OF CAPACITY (_____ max amps)						
ATS TRANSFER (yes / no)						
TRANSFER MONTHLY (date)						
TEST PERFORMED BY (initials)						

NOTES: